



## Minor Forest Produce Processing & Research Centre

(An ISO 9001:2008, EMS 14001:2004 & GMP Certified Unit)

Van Parisar, Barkheda Pathani, Bhopal - 462 021, Madhya Pradesh

Unit of MP State MFP Co-operative Federation Ltd. Bhopal, An undertaking of Govt. of M.P. Co-operative

Tel: (0755) 2970629, 2970630 Fax : (0755) 2970629

Visit at www.vindyaherbals.com E-mail : mfpparc@gmail.com



No.MFP-PARC/Limited Ten./2019/2047

Bhopal, Date 25.07.2019

### NOTICE INVITING LIMITED TENDER FOR SUPPLY OF PHARMA GRADE DEHUMIDIFIER AND ITS ACCESSORIES

The Minor Forest Produce Processing & Research Centre (MFP-PARC), Barkheda Pathani, Bhopal is a unit of MP State MFP Co-operative Federation Ltd. Bhopal, a Govt. of M.P Co-operative undertaking, engaged in manufacturing of Ayurvedic Medicines & Herbal Products under the brand name of **Vindhya Herbals**. Minor Forest Produce Processing & Research Centre (MFP-PARC), invites offline limited tender bid through quotations to supply **"PHARMA GRADE DEHUMIDIFIER and Its ACCESSORIES" With Installation**

Technical Specification as given below:

#### "PHARMA GRADE DEHUMIDIFIER and Its ACCESSORIES" With Installation

Supply of desiccant dehumidifier complete with metal-silicate based desiccant rotor. Rotor should have organic compound less than 2%. Rotor should be adsorbent, non-toxic, non-flammable, and fully water-washable. Rotor should have perimeter flange, and teeth around perimeter flange to ensure a positive and slip-free rotation. Rotor should be made in India. Dehumidifier should have process blower, process motor, process filter, reactivation blower, reactivation motor, reactivation filter, reactivation electric heater, rotor drive motor, thermostat, humidistat and in-built MCB. The dehumidifier casing should be industrial design, CNC fabricated from heavy gauge sheet. It should be powder coated.

S.N	Particulars With Installation	Rate per unit/per meter in Rs. (Excluding tax)
1	300 CMH Process-air @ 200 Pa ESP. Reactivation heater: 3.6 KW, Single-Phase, 50 Hz power supply	
2	170 CMH Process-air @ 120 Pa ESP. Reactivation heaters: 2.3 KW. Single-Phase 50 Hz Power Supply	
3	<u>PVC Hose Pipe: 100 mm dia. Rate per meter</u> Providing and fixing of flexible PVC hose pipe of mentioned diameter for providing process inlet air/process outlet air or reactivation inlet air/reactivation outlet air to the given room/lab for various equipment through walls/ceiling with appropriate clamps & fixing arrangement as per client requirement.	
4	<u>Bird Gauge with clamp (Metallic-mesh at the inlet of suction pipe) 100 mm dia. (Rate per unit)</u> Providing and Fixing of bird gauge with specific clamp of mentioned diameter for PVC hose pipe of process inlet air/process outlet air or reactivation inlet air/reactivation outlet air to the given room/lab.	

The last date of offline limited tender financial bid submission is 02.08.2019 up to 03.30 PM. Financial bid will be opened on 02.08.2019, 4.00 pm at MFP-PARC, Barkheda Pathani, Bhopal by Internal Purchase Committee.

Chief executive officer

